

Abstract Submitted
for the SHOCK19 Meeting of
The American Physical Society

Fast mid-infrared spectroscopy of gases: measurement method during a H_2/O_2 deflagration(symp)¹ MARIE DABOS, CEA-GRAMAT, KHANH-HUNG TRAN, LEME, Paris Nanterre University, NICOLAS LECYSYN, GERARD BAUDIN, CEA-GRAMAT, MARC GENETIER, ISABELLE RANC, BRUNO SERIO, LEME, Paris Nanterre University — To study detonation products of condensed matter containing aluminum particles in the post-combustion phase, a preliminary work is carried on deflagrations. The study of molecules' radiative properties during this fast phenomenon is not simple in the MWIR range. The flame front of H_2/O_2 gas mixtures spreads in a few tens of meters per second, a fast IR detection system is required. Also, there are no standard source in that spectral range for the intensity and spectral position calibration. The important feature of the experimental set-up presented is the record of high-resolution spectra dynamically at high speed, up to 10 kHz. The set-up is composed of a cylindrical combustion chamber with optical accesses. The pressure evolution is measured by a high speed piezoelectric sensor. The ignition is synchronized with the camera trigger. The radiation is focused into a monochromator and at its exit slot a camera records in real time the spectra. The spectral intensity is calibrated using a blackbody. The correspondence between the spatial position of a pixel and the wavelength is fitted using an original method based on the application of a third degree polynomial taking into account optical aberrations. The method is presented with the example of a $\text{H}_2/\text{O}_2/\text{N}_2/\text{CO}_2$ gaseous deflagration. The resulting spectra can be used to determine the temperature and the emissivity of gases.

¹We thank the DGA for its financial support.

MARIE DABOS
CEA-GRAMAT

Date submitted: 26 Feb 2019

Electronic form version 1.4